

Contacte por favor a Hispano Servicios en (920) 465-9491 si ayuda es necesitada a traducir esta carta.

Yog haistias koj tsis toaub diam ntwav no thiab xav tau kev pab txhais, thov hu rau Koomhaum Hmoob ntwam (920) 437-4550



Lawrence Water Utility

2022 Annual Drinking Water Quality Report

The Town of Lawrence is pleased to present to you this year's Annual Water Quality Report. The report is designed to inform you about the water quality and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. In August 2007, the Town began receiving Lake Michigan water from Manitowoc via the Central Brown County Water Authority pipeline to our meter station. We are still required to monitor the water quality of our well under an agreement with the DNR, even though it will be only used for emergency purposes.

This report shows our water quality and what it means. We want our valued customers to be informed about their water utility. If you have any questions about this report, the water utility, or wish to obtain a copy of the source water assessment, please contact our office at Lawrence Town Hall, 2400 Shady Court or call (920) 336-9131. If you want to learn more, or if you have questions, the Town of Lawrence Town Board meets on the second and fourth Mondays each month at 6:30pm at the Town Hall located at 2400 Shady Court, De Pere, WI. At the meeting, there is an agenda item where the general public can ask questions or speak on any subject matter. You may also visit the Town of Lawrence website at www.lawrencewi.gov

The Lawrence Water Utility routinely monitors for potential contaminants in your drinking water according to State and Federal laws. This report shows the results of our monitoring for the period of January 1 to December 30, 2022. This is our ultimate goal and objective is to provide our residents the safest high-quality water possible.

Source of Water

The Emergency well was not activated in 2022

Source ID	Source	Depth (In feet)	Status
2 and 3	Purchased Surface Water from PWS ID 43603645 Manitowoc Waterworks through PWS ID 43602878 Central Brown County Water Authority		Active

Health Information

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's safe drinking water hotline at 1-(800) 426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, persons with HIV/AIDS or other immune system disorders, some elderly, or infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Environmental Protection Agency's safe drinking water hotline 1-(800)426-4791.

Educational Information

The sources of drinking water, both tap water and bottled water, include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

Microbial contaminants such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.

Inorganic contaminants such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

Pesticides and herbicides which may come from a variety of sources such as agriculture, urban stormwater runoff and residential uses.

Organic chemical contaminants including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff and septic systems.

Radioactive contaminants which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in the water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which shall provide the same protection for public health.

Distribution System Results

Your water was tested for many contaminants last year. We are allowed to monitor for some contaminants less frequently than once a year. The following tables list only those contaminants which were detected in your water. If a contaminant was detected last year, it will appear in the following tables without a sample date. If the contaminant was not monitored last year, but was detected within the last five(5) years, it will appear in the next table along with the sample date.

Disinfection Byproducts

Contaminant (Units)	Site	MCL	MCLG	Level Found	Range	Violation	Typical Source of Contaminant
HAA5 (ppb)	IDSESM 3	60	60	7	7	No	By-product of drinking water chlorination
TTHM (ppb)	IDSESM 3	80	0	45.5	45.5	No	By-product of drinking water chlorination
TTHM (ppb)	IDSESM 8	80	0	41.7	41.7	No	By-product of drinking water chlorination
HAA5 (ppb)	IDSESM 8	60	60	23	23	No	By-product of drinking water chlorination



DETECTED CONTAMINANTS

Inorganics

Contaminant (units)	Action Level	MCLG	90th Percentile level found	# of Results	Violation	Typical Source of Contaminant
COPPER (ppm)	AL=1.3	1.3	0.675	0 of 20 results were above the action level	No	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD (ppb)	AL=15	0	1.1	0 of 20 results were above the action level	No	Corrosion of household plumbing systems; Erosion of natural deposits

Additional Health Information

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from material and components associated with service lines and home plumbing. Lawrence Waterworks is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead.

Purchased Water Results

Our water system purchases water from CENTRAL BROWN COUNTY WATER AUTHORITY. In addition to the detected contaminants listed above, these are the results from CENTRAL BROWN COUNTY WATER AUTHORITY.

Inorganic Contaminants

Contaminant (units)	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2021)	Violation	Typical Source of Contaminant
ARSENIC (ppb)	N/A	N/A	N/A	N/A	N/A	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
BARIUM (ppm)	2	2	0.022	0.022		No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
FLUORIDE (ppm)	4	4	0.7	0.7		No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
NICKEL (ppb)	N/A	N/A	N/A	N/A	N/A	No	Nickel occurs naturally in soils, ground water, and surface waters and is often used in electroplating, stainless steel and alloy products
NITRATE-NITRATE (NO3 + NO2) (ppm)	10	10	0.33	0.33		No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
NITRATE (NO3-N) (ppm)	N/A	N/A	N/A	N/A	N/A	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Radioactive Contaminants

Contaminant (units)	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2021)	Violation	Typical Source of Contaminant
RADIUM (226+228) pCi/l)	5	0	0.46	0.46	2/18/2020	No	Erosion of natural deposits
COMBINED URANIUM (uq/l)	30	0	0.313	0.313	2/18/2020	No	Erosion of natural deposits

Synthetic Organic Contaminants including Pesticides and Herbicides

Contaminant (units)	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2021)	Violation	Typical Source of Contaminant
ATRAZINE (ppb)	3	3	0.028	0.028	8/11/2020	No	Runoff from herbicide used on row crops

Unregulated Contaminants

Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted. EPA required us to participate in this monitoring.

Contaminant (units)	Level Found	Range	Sample Date (if prior to 2021)
MANGANESE (ppm)	0.7	0.7	2018 MANITOWOC UCMR 4
SODIUM (ppm)	7.7	7.7	N/A
SULFATE (ppm)	22	22	N/A
METOLACHLOR (DUAL) (ppb)	0.01	0.01	8/11/2020
BROMODICHLOROMETHANE (ppb)	N/A	N/A	N/A
CHLOROFORM (ppb)	N/A	N/A	N/A

Turbidity Monitoring

In accordance with s. NR 810.29, Wisconsin Administrative Code, the treated surface water is monitored for turbidity to confirm the effectiveness of the Manitowoc Water filtration system. Turbidity is a measure of the cloudiness of water. During the year, the highest single, entry point turbidity measurement was 0.08 NTU.

Term	Definition
AL	Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
MCL	Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
MCLG	Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
NTU	Nephelometric Turbidity Units
pCi/l	Picocuries per liter (a measure of radioactivity)
ppm	Parts per million, or milligrams per liter (mg/l)
ppb	Parts per billion, or micrograms per liter (ug/l)